

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 104.

Dated: 24/12/2025

It is certified that an inspection team headed by VIJOY KUMAR / CHEMIST,
DISTRICT LEVEL WATER TESTING LAB, CHHAPRA,
(Name of Officers with designation) from PHED

inspected the DAV PUBLIC SCHOOL, SIDHWALIA, CHHAPRA.

(Name & Address of the school) on 20-12-2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 54 dated 24/12/2025
of DISTRICT LEVEL WATER TESTING LAB, CHHAPRA
(PHED Lab) certified that the

DAV PUBLIC SCHOOL, SIDHWALIA, CHHAPRA
(Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till one year.

Signature with Seal: Vijoy Kumar
Name: VIJOY KUMAR
Designation: CHEMIST
Name & Address of the Office / Department: DISTRICT LEVEL WATER TESTING LAB, CHHAPRA

To
DAV PUBLIC SCHOOL, SIDHWALIA,
CHHAPRA, SARAY, BIHAR
(Name & Address of the Institution) PIN No. 841316

Chemist
DEWOTL
P. H. Division, Chapra

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

DISTRICT LEVEL LABORATORY, CHAPRA (SARAN)

PUBLIC HEALTH DIVISION, CHAPRA

CHEMICAL & BACTERIOLOGICAL EXAMINATION REPORT OF DRINKING WATER SAMPLES

SAMPLE COLLECTED ON 12-12-25 BY S.P. Singh Barui & RECEIVED IN THE LABORATORY ON 12-12-25

SL NO	PARTICULARS OF THE SAMPLE				PARAMETERS EXAMINED (VALUE IN Mg/L except pH. Otherwise Mentioned)														
	Block	Gram Panchayat	Village/ Ward Number	Name of the Nearest person/Institution	Turbidity	pH	Conductivity	Total Hardness	Total Alkalinity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Fluoride	T.D.S	Arsenic	Bacteriological test
1	Chapra	Chapra Sadar		Dav Public School, Sidhwalia Chapra CBSE Affiliated School Affiliation no- 330832	1	7.4	490	170	190	40	14.4	25	20	0.02	0	0.03	290	BDL	-ve
Min-Max Permissible Limit (IS:10500/2012)					1-5 NTU	6.5 8.5	-	200 600	200 600	75 200	30 100	250 1000	200 400	1.0 NR	45 NR	1 1.5	500 2000	0.01 NR	+VE -VE

Remarks: *Analysed Sample of water within permissible limit.*

Memo No 54 / Chapra, Dated 24-12-2025

Copy forwarded to Executive Engineer, P.H division, Chapra/AE
P.H sub division, Chapra/Mashrakh/Sonepur/I.E.P.H section

*BDL-Below detection limit.

Vijay Kumar
24/12/2025
Signature of the Chemist
Chemist
DLWOTL
P.H. Division, Chapra